

# ZW32-24/630-20 Catalogue

Outdoor high vacuum circuit breaker











For Reliable, Secure and Economical Energy System Operation



#### 1. General Overview

This manual is not a substitute for the operating procedures of electrical equipment and cannot contain all safety rules for electrical installation and operation. The users must follow the safety rules for high-voltage operation of electrical systems and strictly comply with their provisions. Otherwise, the company will not be responsible for any accidents caused by them.

This manual is a general version, the actual parameters of the product may be different from this manual. In this case, the product order shall prevail.

### 1.1 Application

ZW32-24 series outdoor high vacuum breaker is circuit outdoor power distribution equipment with rated voltage 24kV and three-phase AC 50Hz. It is mainly used to open and close the load current, overload current and shortcircuit current in the power system. It is suitable for protection and control in substations and distribution systems of industrial and mining enterprises, and more suitable for rural power grids and places of frequent operation.

This instruction manual specifies the referenced standards for circuit breakers, environmental conditions for use, model and rated parameters, structural features, operating principles, ordering instructions, and the principles and methods of operation, installation, use and maintenance.


### &RPSRVLWLRQ DQG PHDQLQJ RI WKH SURGXFV

## (QYLURQPHQWDO FRQGLWLRQV RI XVH

1 R		1 D P H		LW	6 W D	QGD	U G	SDUD
		OD[LPXP WHPS	HUDWXNH					
	\$PELHQ\	V DĽRUZHVW 7HPSH	HUDWXUH					
	WHPSHU	DOWDX UPIXP GDLO\	WHPSHUDV	VXUH				
		GLIIHUHQF	<del>-</del>					
		(OHYDWLRQ		Р		"		
	6 R O D	U UDGLDWLRQ LO	WHQVLW\	RXWG	RRU		] :	: FP
		)LOWK OHYHO					á	
	7 K	(LFNQHVV  RI LFH	FRY <b>F</b> IP					
	:LQG \	/SHHG ZLQG SU	HVVXUH F	XWGRF	₹U		Pν	/ 3 D
		\$YHUDJH GDLC	)\ UHODWL	ΥH	"			
	+ X P L G L	W\ KXPLGLW\						
	+XI LGL	\$YHUDJH PRQW	KO\ UHOD	WLYH	"			
		KXPLGLW\						
	(DUWKT)	RUL]RQWD	0					
	HHVIVV	<sup>M                                    </sup>	RQ YPHUVWL	FDO	J15g			
	FDSDFL	W/ BITTIONOBY	LIVE				]	
	וטטטו	''' ' 6LQH UHV	'RQDQW W	ULSOH	ZDYH	ZLW	Κ \	/DIHW



## 1.4 Equipment size





### 1.5 Main technical parameters

### Main technical parameters of circuit breaker

No.	Item			alue		
1	Rated voltage			24		
2		Rated frequency	Hz	50		
3	Rated current			630		
4	Rated short-circuit breaking current			20 (25)		
5	Rated peak withstand current			50 (63)		
6	Rated short-time withstand current/duration			20/4 (25/4)		
7	Rated short-circuit closing current (peak)			50 (63)		
8	Rated operating sequence			0-0.3s-co-180s-co		
9	Mechanical life			10000		
10	Rated short-circuit current opening and closing times			30		
11	1min frequency withstand voltage	(Dry) Interphase, ground/break	kV	50/70		
12	Lightning surge withstand voltage (peak) phase to phase, ground to ground/break		kV	125/170		
13	Secondary circ	cuit 1min frequency withstand voltage	V	2000		

### Main mechanical characteristics of circuit breakers

NT -	T4	Unit	X 7- 1
No.	Item		Value
1	Contact opening distance	mm	12±1
2	Contact overtravel	mm	3±1
3	Breaking speed	m/s	1.4±0.2
4	Closing speed	m/s	0.8±0.2
5	Contact closing bounce time	ms	2
6	Interphase center distance	mm	380±1.5
7	Three-phase division (closing) is not simultaneous	ms	2
8	Loop resistance		80
9	Closing time	Ms	60
10	Breaking time	Ms	50
11	Rated power of energy storage motor	W	40



### 2. Basic components

#### 2.1 Vacuum interrupter

ZW32-24 type circuit breaker adopts domestic high-quality brand vacuum interrupter chamber, through the tube vacuum excellent insulation to make the medium and high voltage circuit cut off the power supply can quickly extinguish the arc and suppress the current to avoid accidents and accidents.

#### 2.2 Operating mechanism

ZW32-24 type circuit breaker adopts simple and reliable spring-operated mechanism, sealed inside the switch box, which can effectively avoid the rusting of the mechanism caused by the switch in long-term outdoor environment. It can realize electric energystorage opening and closing and manual energy-storage opening and closing, which is convenient for operation.

#### 2.3 Current Transformer

ZW32-24 type circuit breaker can be installed with phase sequence and zero sequence current transformer, and used in conjunction with the controller, which can be used for line

current measurement and protection. If needed, zero sequence voltage sensor can also be installed.

#### 3. Features

- 1 Flexible operation: This product can realize electric energy storage, electric splitting and closing, and also has manual energy storage, manual splitting and closing function.
  - Facilitating field operations;
- With maintenance-free characteristics; the main circuit of the circuit breaker and the secondary components and operating mechanism are sealed in the box, not

- affected by the external environment;
- 3 Excellent external insulation performance: the three-phase insulating sleeve is made of silicone rubber/epoxy resin for outdoor use, which has many advantages of stopping surface discharge, good water repellent performance, UV resistance and high mechanical strength;



### 4. Installation and commissioning

"WARNING": When lifting and installing equipment, follow local recommendations for safe operation. Please use the lifting ring on the circuit breaker. Please lift the equipment

smoothly to ensure that the center of gravity of the breaker does not shift and that the breaker is not allowed to swing significantly. Improper lifting may result in equipment damage.

#### 4.1 Lifting of equipment

ZW32-24 circuit breaker in the process of transport should be maintained in the closed position, shall not be turned upside down, lifting hooks must be hooked in the ZW32-24

circuit breaker lifting ring, and maintain the level of lifting, with special attention to the lifting rope can not act directly on the sleeve.

#### 4.2 Fixing of equipment


ZW32-24 circuit breaker is suitable for most of the standard mounting brackets, the user can provide their own mounting brackets, or the manufacturer can provide mounting bracket accessories to fix the ZW32-24 circuit breaker mounting bracket on the pole.

### 4.3 On-site installation guidance

- A. Delivery to the site for vertical mounting tests of the circuit breakers as required;
- B. Ensuring that the poles are strong enough to support the circuit breakers;
- C. Mount the mounting bracket of the ZW32-24 circuit breaker firmly on the pole;
- D. Lifting the ZW32-24 circuit breaker to a suitable position and fixing it to the mounting bracket;
- E. Reasonable high-voltage electrical connections according to the site conditions, and the lead wires on both sides of the ZW32-24 circuit breaker switch should have a certain degree of slack to prevent the lead wires from generating excessive stress on the product;
- F. Turn on the controller power, if the DC power supply should be used to ensure the correct wiring of the positive and negative power supply.



## **Installation schematic**





#### 4.4 Field trials

#### **Insulation withstand voltage test**

The high voltage withstand test of the body of the ZW32-24 type circuit breaker switch should be conducted at 50Hz, phase to phase, 31.5kV to ground, and 36.8kV at the break (75% of the rated frequency withstand voltage).

"Note": When testing, the controller must be connected to the body of the circuit breaker or CT short, and the controller and circuit breaker box should be reliably grounded.

#### A.) Test 1 to ground operating procedures:

Close the main contact of the circuit breaker switch Ground the circuit breaker body reliably

Connecting the three power side terminals together

Apply the test voltage to the power side terminal

The circuit breaker should be able to withstand the test voltage for 60 seconds

#### **B.**) Test 2 interphase operating procedure:

Close the main contact of the circuit breaker switch

Ground the circuit breaker switch body reliably

Ground the A-phase and C-phase load

side terminals

Apply test voltage to B-phase power side terminal

Breaker switch should be able to withstand the test voltage for 60 seconds

#### C.) Test 3 fracture operation procedure:

Open the main contact of the circuit breaker switch

Ground the circuit breaker switch body reliably

Connect the load side terminals together and ground them reliably

Connecting the power side terminals together

Apply test voltage to the power side

terminals

Breaker switch should be able to withstand the test voltage for 60 seconds. Change the wiring, connect the power side terminals together and ground, connect the load side terminals together, then apply the test voltage to the load side terminals, the circuit breaker can withstand the test voltage for 60 seconds.



### 5. Application and Maintenance

"WARNING": The user must select the circuit breaker correctly for the purpose for which it is to be used. The circuit breaker must be properly installed and operated by personnel who are trained and familiar with the installation procedures. These safety

warnings are not a substitute for proper safety training and a certain level of safety experience. Incorrect selection, installation or maintenance of the switch may result in death or serious personal injury.

#### **Application**

Before the circuit breaker is put into operation, the rated voltage and rated current of each operating element should be carefully checked to see if they match the actual situation, and operated with the closing and dividing mode that the mechanism has to check if the indicators are correct. If the supporting controller is used, it is necessary to confirm

Dongfang Electronics International Engineering Co., Ltd.

Dongfang Electronics Co., Ltd.

Address: 2 Jichang Road, Yantai, Shandong Province, P.R. China, 264000

Tel: +86-535-5520925 Fax: +86-535-5520930

Email: idf@dongfang-china.com

Website: <a href="http://www.dongfang-china.com/en">http://www.dongfang-china.com/en</a>



THE INFORMATION CONTAINED IN THIS DOCUMENT IS THE PROPERTY OF DONGFANG ELECTRONICS INTERNATIONAL ENGINEERING CO., LTD. ALL RIGHTS RESERVED.